



COMPATIBILITY REPORT

According to:
Technical Requirements for DVV, 8th edition, May 2023
Annex 18: Compatibility - glazing units

Following sealants are **COMPATIBLE** with our sealant **POLIVER F**

Reference	Adhesive	Manufacturer	Color	Batch	Average change in mass, % ($\leq 3,5\%$)	Average change in hardness (≤ 12)	Bending test
DVV2025-001	Ottocoll S 88	Ottocoll	Black	52531252	-2,3%	0	Passed
DVV2025-002	Ottocoll S-SP 7981	Ottocoll	Black	51292051	-1,0%	-7	Passed
DVV2025-004	Danaseal 515	Dana Lim	Black	52950705	-3,5%	10	Passed
DVV2025-005	ProFect 11801 SG20S	Dana Lim	Transparent	52806157	-2,4%	10	Passed
DVV2025-006	ProFect 11800 SG60S	Dana Lim	Black	52813103	-1,4%	6	Passed
DVV2025-013	Silirub 2	Soudal	Transparent	221664291	-2,3%	9	Passed
DVV2025-014	ProFect 11801 SG20S	Dana Lim	Black	53618705	-1,6%	9	Passed
DVV2025-015	Danaseal 514	Dana Lim	Transparent	52706156	-3,3%	12	Passed
DVV2025-016	Dowsil 791	Dow	Black	H041P1L061	-2,4%	12	Passed
DVV2025-017	Dowsil 796	Dow	Black	H041P7I055	-2,3%	10	Passed
DVV2025-018	Dowsil 799	Dow	Transparent	H041P42999	-2,8%	7	Passed
DVV2025-019	Dowsil 895	Dow	Black	H041DAQO43	-2,4%	10	Passed

Tests were carried out in 2025 4th quarter.

NOTE:

Compatibility statement is valid only for tested materials. Since we have no control over the manufacture or formulation of these materials, Fenzi S.p.A. makes no guarantee of results and assumes no liability for damages occurred by following these suggestions. This Compatibility statement is valid only in case of Standard Window Glazing.